



	Ref.	Rect2
Emiss.	1.0	1.0
Avg		40.8 °C
Min		30.0 °C
Max	32.2 °C	53.3 °C
Delta		21.1 °C

Equipment	Buss on top of Delta-Wye Switch
Location	16 FCE
Condition	Overheating
Causes	Loose, dirty, or corroded connection.
Load	Unknown
Temperature Rise	21.1°C
Repair Priority Level	Level 4: Major discrepancy; repair immediately.
Action Suggested	Inspect, clean, and tighten connection.
Repairs Completed By:	

Repairs Completed On:

Date: 10/16/2005 Thermographer: J. Devi Thorp